

**Park Ridge Water Department
Secondary Standards (primarily aesthetic)**

Parameter (units)	Recommended Upper Limit	Park Ridge Average	Park Ridge Range		
			Min	to	Max
ABS/L.A.S.(ppm)	0.5	0.007	ND	to	0.015
Alkalinity (ppm)	NA	136.6	118	to	165
Aluminum (ppm)	0.2	BMDL			
Chloride (ppm)	250	43	6	to	77
Color(color units)	10	BMDL			
Copper (ppm)	1	0.028	ND	to	0.41
Corrosivity (ppm)	+/- 1.0	0.11	-0.46	to	0.86
Fluoride (ppm)	1.2	0.027	ND	to	0.1
Hardness (ppm)	50-250	215	124	to	368
Iron (ppm)	0.3	BMDL			
Manganese (ppm)	0.05	BMDL			
Odor (threshold odor number)	3	BMDL			
pH	6.5-8.5	7.72	7.02	to	8.42
Silver (ppm)	0.1	BMDL			
Sulfate (ppm)	250	32.79	9	to	106.8
Total Dissolved Solids (ppm)	500	333	140	to	488
Zinc (ppm)	5	0.001	ND	to	0.02

BMDL - Below Minimum Detection Levels

ppm - parts per million or mg/L

Park Ridge Average - average of sampling at 14 points of entry

Park Ridge Range - minimum and maximum levels at 14 points of entry