



**BOROUGH OF PARK RIDGE
BOARD OF PUBLIC WORKS
ANNUAL WATER QUALITY REPORT
JUNE 2023 (2022 SAMPLING DATA)**

KEITH MISCIAGNA
MAYOR
JEFF RUTOWSKI
PRESIDENT
MICHAEL MINTZ
VICE PRESIDENT
SEAN MCNAMARA
FRANK PANTALEO
JOHN COZZI
COUNCIL LIAISON

Landlords must distribute this information to every tenant as soon as practicable, but no later than three business days after receipt. Delivery must be done by hand, mail, or email, and by posting the information in a prominent location at the entrance of each rental premises, pursuant to section 3 of P.L. 2021, c. 82 (C.58:12A-12.4 et seq.).

The Park Ridge Water Department is pleased to present this year's Annual Water Quality Report. This report details the results of our water quality testing performed in 2022. It is designed to inform you about the quality water and services we provide to you every day. Our goal is to provide you with a safe and dependable supply of potable drinking water.

In 2022, we analyzed over 2,500 samples to ensure that the 746 million gallons of water we pump, treat, and deliver meets water quality standards. We are pleased to report that we have met all of the federal drinking water standards, and only exceeded one new State standard.

The Board of Public Works is committed to delivering a safe and reliable supply of drinking water to the over 5,000 customers in Park Ridge and Woodcliff Lake. This has been the consistent goal since the water utility began its operation in the 1920's.

This publication is very important because informed customers are the best allies in maintaining safe drinking water. Regular meetings of the Park Ridge Board of Public Works normally occur on the first and third Wednesday of each month, at 8:00 PM at the Park Ridge Utility Department, 15 Sulak Lane, Park Ridge. These meeting are now being held virtually with conferencing software. The public is welcome to attend and information on how to join the virtual meeting is posted on the Park Ridge Borough's website (www.parkridgeboro.com) prior to the meeting.

If you have any questions about your water please call us at (201) 391-2113. Additional information is also available on the Borough's website at www.parkridgeboro.com. You may also call the Environmental Protection Agency safe drinking water hotline at (800) 426-4791 or find it on EPA's web site at www.epa.gov.

Where does our water come from?

Our water is supplied by groundwater from 18 wells located throughout Park Ridge and Woodcliff Lake. This water is drawn from the Brunswick Aquifer. In addition, we have three water storage tanks and five booster stations which can transfer water between different parts of the distribution system.

IMPORTANT PHONE NUMBERS

Park Ridge Water Department Chris O'Leary - Licensed Operator	201-391-2113	NJDEP Bureau of Safe Drinking Water	1-609-292-5550
To report water emergencies during non-business hours	201-391-5400	New Jersey Board of Public Utilities	1-800-624-0241
New Jersey State Department of Environmental Protection (NJDEP)	1-609-292-3950	Environmental Protection Agency's Safe Drinking Water Hotline	1-800-426-4791

Drinking Water Quality Table

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Substance	Violation Y/N?	Units	EPA Goal MCLG	NJDEP Standard MCL	*Park Ridge Detected Level	Park Ridge Range	Major Sources
Inorganic Chemicals (Nitrate tested 2022, all others tested 2020)							
Nitrate	No	ppm	10	10	3.0	1.22 - 3.0	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Arsenic	No	ppb	NA	5**	4.72	ND - 4.72	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium	No	ppm	2	2	0.598	0.09 - 0.598	Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits
Chromium	No	ppb	100	100	5.85	ND - 5.85	Discharge from steel and pulp mills; Erosion of natural deposits
Nickel	No	ppb	NA	NA	2.95	0.97 - 2.95	Erosion of natural deposits
<i>(This category contains 11 additional constituents which were not detected)</i>							

Microbiological

Total Coliform	No		0	TT	1	1	Naturally present in the environment
Disinfectant Residual (Chlorine)	No	ppm	MRDLG=4	MRDL=4	0.33	0.1 - 0.81	Water additive used to control microbes

Over 180 samples were collected throughout the year from our distribution system.

Radionuclides (Well #20 tested in 2020. All other wells tested in 2017)

Alpha Emitters	No	pCi/L	0	15	7.3	1.5 - 7.3	Erosion of natural deposits
Combined Radium 226/228	No	pCi/L	0	5	1.46	0.6 - 1.46	Erosion of natural deposits
Radon (tested 6/28/99)	No	pCi/L	n/a	n/a	790	n/a	Erosion of natural deposits

Organic Chemicals

cis 1,2 Dichloroethylene	No	ppb	70	70	0.68	ND - 0.68	Discharge from industrial chemical factories
Methyl Tertiary-Butyl Ether	No	ppb	70***	70	0.85	ND - 1.67	Leaking underground gasoline and fuel oil tanks, gasoline and fuel oil spills
Trichloroethylene	No	ppb	0	1**	0.05	ND - 0.22	Discharge from metal degreasing sites and other factories

Per- and polyfluoroalkyl (PFAS) Compounds

Perfluorononanoic Acid (PFNA)	No	ppt	NA	13**	6.2	ND - 10.1	Discharge from industrial chemical factories
Perfluorooctanic acid (PFOA)	No****	ppt	NA	14**	10.8*	ND - 12.8	Discharge from industrial, chemical factories, and manufacturing factories, release of aqueous film forming foam.
Perfluorooctanesulfonic acid (PFOS)	No	ppt	NA	13**	12.3*	ND - 11.1	Discharge from industrial, chemical factories, release of aqueous film forming foam.

Disinfectant By-Products (DBPs)

Total Trihalomethanes (TTHM)	No	ppb	n/a	80	17.43	3.02 - 31.3	By-product of drinking water disinfection
Five Haloacetic Acids (HAA5)	No	ppb	n/a	60	3.38	ND - 3.51	By-product of drinking water disinfection

* Park Ridge detected level shows the highest test results used to determine compliance for the year in 2022. For some contaminants, this level is the running annual average of data from the highest entry point.

State standard lower than Federal standard. * NJDEP regulated chemical. MCLG is health-based number developed by the NJDEP.

**** Park Ridge removed one well which exceeded the PFOA MCL in 2021 from service pending permanent treatment and temporary treatment was installed on the other two wells which exceeded the MCL in 2021. Quarterly public notices from the 2021 PFOA exceedance will continue

Lead and Copper (tested in 2022)

Substance	Violation Y/N?	Units	Action Level (AL)	Number of Samples	90th Percentile	Samples above the AL	Major Sources
Lead	No	ppb	15	30	0	1	Corrosion of household plumbing systems; erosion of natural deposits
Copper	No	ppm	1.3	30	0.591	0	Corrosion of household plumbing systems; erosion of natural deposits

Drinking Water Quality Table (continued)

Secondary Standards - related to aesthetic quality of drinking water (tested in 2020, some sodium sampling in 2022)

	Units	NJ RUL	Average Park Ridge Result	Park Ridge Range	Major Sources
Chloride	ppm	250	127	69 - 211	Natural Mineral - Road Salt
Hardness	ppm	250	350	230 - 481	Natural Mineral
Manganese	ppm	0.05	0.001	ND - 0.013	Natural Mineral
Sodium	ppm	50	50.6	13.4 - 96.4	Natural Mineral - Road Salt
Sulfate	ppm	250	21.6	6 - 67	Natural Mineral
Zinc	ppm	5	0.003	ND - 0.023	Natural Mineral
Total Dissolved Solids	ppm	500	619	411 - 906	Erosion of Natural Mineral Deposits
pH		6.5 - 8.5	7.31	6.63 - 7.87	Natural Characteristic

Note: The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

Unregulated Compounds

Substance	Units	Standard	Average Park Ridge Result	Park Ridge Range	Major Sources
Perchlorate (2022)	ppb	None	1.06	ND- 2.18	Oxygen additive in solid fuel propellant for rockets, missiles, & fireworks; fertilizers; erosion of natural deposits.

Unregulated Contaminants Monitoring Rule (UCMR4)

During 2020, Park Ridge Water participated in the fourth phase of the Unregulated Contaminant Monitoring as required by the USEPA. Unregulated contaminants are those for which the USEPA has not established drinking water standards. Monitoring assists the USEPA in determining the occurrence of these compounds and whether or not future regulation is warranted. Detections from this monitoring are summarized in the following table, along with typical sources of these compounds. More information is available at <https://www.epa.gov/dwucmr/fourth-unregulated-contaminant-monitoring-rule>

Substance	Units	Standard	Average Park Ridge Result	Park Ridge Range	Major Sources
Manganese	ppb	None	1.43	ND - 10.9	Naturally-occurring element; commercially available in combination with other elements and minerals; used in steel production, fertilizer, batteries and fireworks; drinking water and wastewater treatment chemical; essential nutrient
Haloacetic Acids (HAA5)	ppb	None	2.8	0.7 - 5.8	By-product of drinking water disinfection
Haloacetic Acids (HAA6Br)	ppb	None	4.6	1.0 - 8.9	By-product of drinking water disinfection
Haloacetic Acids (HAA9)	ppb	None	5.0	1.0 - 9.6	By-product of drinking water disinfection

Definitions:

MCLG (Maximum Contaminant Level Goal) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety

MCL (Maximum Contaminant Level) - The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology

MRDL (Maximum Residual Disinfectant Level) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants

MRDLG (Maximum Residual Disinfectant Level Goal) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination

NJRUL - New Jersey Recommended Upper Limit

ND (non-detects) - laboratory analysis indicates that the constituent is not present above the reporting limit

ppm (parts per million) - one drop in 10 gallons, one minute in two years, or a single penny in \$10,000

ppb (parts per billion) - one drop in 10,000 gallons, one minute in 2,000 years

ppt (parts per trillion) - one drop in 10,000,000 gallons, one minute in 2,000,000 years

pCi/L (picocuries per liter) - measure of the radioactivity in water

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers a treatment or other requirements which a water system must follow

Treatment Technique (TT) - A required process to reduce the level of a contaminant in drinking water

What Does This Table Mean?

The New Jersey Department of Environmental Protection (NJDEP) is the primary agency authorized by the United States Environmental Protection Agency (EPA) to regulate the quality of drinking water, and ensure that community water systems comply with State and Federal Regulations. The NJDEP determines the highest level of a contaminant that is allowed in the drinking water or the Maximum Contaminant Level (MCL). Our water is tested to ensure that it is safe. Major Sources shows where this substance usually originates. Range shows the highest and lowest results for the year. Definitions explain the abbreviations used in the table. We ran many analytical tests on our water, and only the listed substances in the table were detected. The Safe Drinking Water Act regulations allow monitoring waivers to reduce or eliminate the monitoring requirements for certain contaminants. We received waivers for asbestos and synthetic organic chemicals because vulnerability assessments were performed and unambiguously showed that our system is not at risk of contamination from these contaminants.

Source Water Assessment Program

The New Jersey Department of Environmental Protection (NJDEP) has completed and issued the Source Water Assessment Report and Summary for our public water system, which is available at www.state.nj.us/dep/swap or by contacting the NJDEP, Bureau of Safe Drinking Water at 609-292-5550.

The Source Water assessment performed on 19 wells determined the following susceptibility ratings for each of the groundwater supply wells. This table illustrates the susceptibility rating for each individual well and contamination category.

Susceptibility Rating for Drinking Water Sources																								
Contaminant Category																								
Sources	Pathogens Rating			Nutrients Rating			Pesticides Rating			VOC Rating			Inorganics Rating			Radionuclides Rating			Radon Rating			DBP Rating		
	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L
Wells - 20*		20		11	9			4	16	20			9	11		6	14		20			3	17	

* The NJDEP has not yet performed the source water assessment for Well #20. The susceptibility ratings will be similar to a nearby well.

L,M,H: Low, Medium and High susceptibility

Pathogens: Disease-causing organisms such as bacteria, protozoa, and viruses. Common sources are animal and human fecal wastes.

Nutrients: Common types of nutrients include nitrogen and phosphorous. Common sources include discharge from septic fields, areas where animal waste is stored, and runoff from agricultural and residential land where fertilizers were used.

Pesticides: Pesticides are manmade chemicals used to control bacteria, fungi, weeds, rodents, and insects. Common sources of pesticides include land applications (nonpoint source) and manufacturing/distribution centers of pesticides (point source).

Volatile Organic Compounds (VOCs): Man-made chemicals that are used as solvents, degreasers, and gasoline components. VOCs are the most common organic contaminants in groundwater in New Jersey.

Inorganics: Mineral-based compounds that are both naturally occurring and manmade. Common sources include discharges from manufacturing plants, releases from contaminated sites, past land uses, and naturally occurring sources. Inorganics include arsenic, cadmium, copper, lead, mercury, and asbestos.

Radionuclides: Radioactive substances that are both naturally occurring and manmade, such as radium and radon. Common sources include the decay of naturally occurring minerals, leaching of subsurface material (for example rocks and sedimentary materials) into ground water, and improper disposal of radioactive waste.

Disinfection Byproduct (DBP) Precursors: Disinfection byproducts are formed when the disinfectants used to kill pathogens during treatment react with dissolved organic material present in the water.

If a source was rated highly susceptible for a contamination category, it does not mean a customer is or will be consuming contaminated drinking water. The rating reflects the potential for contamination of source water, not the existence of contamination. Public Water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels. If you have any questions regarding the source water assessment report or summary, please contact the Bureau of Safe Drinking Water at swap@dep.state.nj.us or 609-292-5550.

Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Park Ridge Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or <http://www.epa.gov/safewater/lead>.

However, for those served by a lead service line, flushing times may vary based on the length of the service line and plumbing configuration in your home. If your home is set back further from the street a longer flushing time may be needed. To conserve water, other household water usage activities such as showering, washing clothes, and running the dishwasher are effective methods of flushing out water from a service line. To determine if you have a lead service line, contact us at 201-822-3136.

Call us at 201-822-3136 to find out how to get your water tested for lead. Testing is essential because you cannot see, taste, or smell lead in drinking water. Park Ridge does not provide free lead testing of customer water, but will provide a list of labs certified by the NJDEP for lead analyses.

NJDEP & EPA HEALTH NOTES

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.
- Arsenic: While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.
- Radon: Radon is a radioactive gas that you can't see, taste or smell. At high levels of exposure, it is a known carcinogen. Radon is found throughout the U.S. in soil and can move up through the ground and into a home through cracks and holes in the foundation. It can also get into indoor air when released from tap water used for showering and other household activities. Radon entering the home through tap water will in most cases be a

small source of radon in indoor air. If you are concerned about radon in your home, have the air tested. It is inexpensive and easy. There are simple ways to fix a radon problem that are not too costly. Call the EPA Radon Hotline for more information at 1-800-SOS-RADON.

- Manganese: The recommended upper limit for manganese is based on staining of laundry. Manganese is an essential nutrient, and toxicity is not expected from levels which would be encountered in drinking water.
- Sodium: For healthy individuals, the sodium intake from water is not important, because a much greater intake of sodium takes place from salt in the diet. However, sodium levels above the recommended upper limit may be a concern to individuals on a sodium restricted diet.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

PFAS – Continued Elevated Concentrations - Per- and polyfluoroalkyl substances (PFAS) are a group of manmade chemicals that have been used in industrial and commercial applications for over 70 years. PFAS are used in the production of some non-stick cookware, in waterproof and stain proof coatings, in “leak-proof” coatings on food package materials, in fire-fighting foams, and in other uses. PFAS can enter drinking water through industrial release to water, air, or soil; discharges from sewage treatment plants; land application of contaminated sludge; and use of fire-fighting foam. The Borough tests for three types of New Jersey regulated PFAS chemicals: PFNA, PFOA, and PFOS. As first reported to you in 2021, our water system violated the New Jersey drinking water standard for PFOA which became effective in 2021 at three wells. As our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation. We are required to update and repeat public notification every quarter until permanent treatment is operational, and the water system returns to compliance, so you will be receiving additional PFAS notification letters until the new water treatment facilities are online.

PFOA first exceeded the NJ MCL in the fourth quarter of 2021. Three affected wells were immediately removed from service. Temporary treatment was installed at two locations and continues to treat the water. The third well remains offline. We expect to award a contract in 2023 to construct the water treatment facilities, with the facilities coming online in 2023 to mid-2024. We will keep you updated with each quarterly public notice.

Some people who drink water containing PFOS in excess of the MCL over many years could experience problems with their immune system, kidney, liver, or endocrine system. For females, drinking water containing PFOS in excess of the MCL over many years may cause developmental effects and problems with the immune system, liver, or endocrine system in a fetus and/or an infant. Some of these developmental effects can persist through childhood.

People who drink water containing PFOA in excess of the MCL over time could experience problems with their blood serum cholesterol levels, liver, kidney, immune system, or, in males, the reproductive system. Drinking water containing PFOA in excess of the MCL over time may also increase the risk of testicular and kidney cancer. For females, drinking water containing PFOA in excess of the MCL over time may cause developmental delays in a fetus and/or an infant. Some of these developmental effects may persist through childhood.

What should I do?

If you have specific health concerns, a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at higher risk than other individuals and should seek advice from your health care providers about drinking this water.

The New Jersey Department of Health advises that infant formula and other beverages for infants, such as juice, should be prepared with bottled water when PFOA and/or PFOS is elevated in drinking water.

Pregnant, nursing, and women considering having children may choose to use bottled water for drinking and cooking to reduce exposure to PFOA and/or PFOS.

Other people may also choose to use bottled water for drinking and cooking to reduce exposure to PFOA and/or PFOS or a home water filter that is certified to reduce levels of PFOA and/or PFOS. Home water treatment devices are available that can reduce levels of PFOA and/or PFOS. For more specific information regarding the effectiveness of home water filters for reducing PFOA and/or PFOS, visit the National Sanitation Foundation (NSF) International website, <http://www.nsf.org/>.

Boiling your water will not remove PFOA and/or PFOS.

More information regarding PFOA and PFOS can be found on the Borough Water Department Webpage: <https://www.parkridgeboro.com/departments/water-sewer> or at <https://dep.nj.gov/pfas/about/>.

Please share this PFAS and VOC information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PROJECTS WE ARE DOING TO IMPROVE OUR WATER SYSTEM

- ◆ Design and permitting for the installation of Permanent PFOA treatment at Wells 12, 14, and 18.
- ◆ Water main flushing and Fire Hydrant maintenance program.
- ◆ Based on the availability and delivery time of new Meters, we will continue the implementation of the New Jersey Board of Public Utilities mandated water meter replacement and testing program.
- ◆ Performing our annual street-by-street leak detection survey and Water main flushing program.
- ◆ Ongoing water pumping facility upgrades.
- ◆ Continuing our water valve testing and exercising program.

How to Use Your Water Meter to Check for Leaks

Park Ridge has two types of water meters, and both can be used to help determine if you have a leak in your house. One type has mechanical totalizing digits which advance every 10 gallons. These meters have a leak indicator that will spin even when the smallest amount of water is passing through your meter. If you have all of your faucets off, and this indicator is moving, this means water is leaking somewhere.

Another type of meter has an electronic digital display that is visible when you open the cover of the meter. The totalizing resolution with these meters is much smaller and will advance even if a small amount of water is running through the meter. In addition, when you open and close the lid, the display will toggle between the total gallons measure and the instantaneous flow rate (in gallons per minute). This can be useful if you are interested in knowing how much water is being used by your appliances or sprinkler system while they are running.

Mechanical Totalizing Meter



LEAK INDICATOR
rotates even for very low
flow of water.

Digital Totalizing Meter



Totalizer advances for
very low flow rates (less
than 1/4 gallon per mi-
nute).
Open and close lid to
display instantaneous
flow rate (gallons per
minute).

Another tip is to read your water meter at night and then first thing in the morning. If there is an increase in the reading, water is leaking in your home. If you have any questions about this, please feel free to call the Water Department at 201-319-2113.

Water Conservation Tips

- ◆ Wash full loads in your washing machine, or adjust the water level to reflect the size of the load.
- ◆ Let your pots and pans soak instead of letting the water run while you clean them.
- ◆ Try planting drought-tolerant and regionally adapted plants in areas that are hard to water or that receive little use. This may include narrow strips near sidewalks or driveways and steep hills.
- ◆ Soaker hoses are better than sprays. Install drip-irrigation or soaker hoses for more efficient watering in planting beds and beneath shrubs and trees.
- ◆ Install ultra-low-flush toilets to reduce the amount of water used in each flush.
- ◆ Put dye tablets or food coloring in your toilet tank and wait to see if the color appears in the bowl (without flushing). If it does, you have a leak!
- ◆ Turn the faucet off while you shave, brush your teeth and lather up your hands.
- ◆ Take a short shower instead of a bath. While a five minute shower uses a 12 to 25 gallons, a full tub requires about 70 gallons.



Board of Public Works
Department of Public Utilities
Borough of Park Ridge
53 Park Ave., Park Ridge, N.J. 07656

PRSR STANDARD
US POSTAGE PAID
MAHWAH NJ
Permit No. 104

POSTAL CUSTOMER
Park Ridge Borough, NJ
07656